

Z093-11630

ADDENDUM NUMBER 1

MILWAUKEE COUNTY  
ZOOLOGICAL GARDENS  
WATER VALVE REPLACEMENT AND  
MANHOLE / CATCH BASIN REHABILITATION  
Site #355  
10001 West Bluemound Road  
Milwaukee, WI 53226

Project Number: Z093-11630

Date of Addendum: March 16, 2012

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated February 17, 2012, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

SPECIFICATIONS

Section 01100 – SUMMARY

Article 1.4 E.,

REPLACE the entire paragraph with the following:

- E. Complete shut down of water service may be required for the replacement of one or more valves. In the event that such shut down is required, do not proceed with the shut down until approved by Owner. Notify and obtain approval from Owner 7 days prior to when a shut down is to occur. Reconfirm with Owner 24 hours prior to the scheduled shut down. Coordinate with Owner in all the shut down and reactivate operations.

Article 1.7

ADD the following paragraph:

- G. Due to the presence of Zoo visitors, off-hour work may be required. Additional labor and other costs associated with off-hour work, if any, shall be at the discretion of bidders and shall be reflected in base bids. No claim for additional compensation from Contractor shall be accepted during construction due to such off-hour work.

Section 02924 – SEEDING AND SOIL SUPPLEMENTS

Article 1.3 A. 3

DELETE the entire paragraph item A. 3.

DRAWINGS

Drawing Sheet No. 2 of 18: Add the following General Notes:-

1. For bidding purposes, assume all repair work to be conducted from outside the MH structure.
2. For bidding purposes, assume saw cutting and removal of a 5'x5' pavement around each MH to receive work.
3. All pavement materials removed shall be disposed off site in a legal manner. Clean sub-pavement soil excavation spoil may be disposed at a Zoo location to be designated by Owner.
4. Repair and replacement of pavement shall be in kind.

Drawing Sheet No. 3 of 18: Add the following General Notes:-

1. For bidding purposes, assume excavation size to be 20'x20'x8'deep each.
2. For bidding purposes assume soil type to be soft sandy clay with trace gravels.
3. All pavement materials removed shall be disposed off site in a legal manner. Clean sub-pavement soil excavation spoil may be disposed at a Zoo location to be designated by Owner.
4. Repair and replacement of pavement shall be in kind.

End of Addendum No. 1